

2098-1xxx SERIES

Remote Indicators

DESCRIPTION

The 2098-1xxx range of remote indicators provide remote indication of an alarm condition on a detector fitted to a 4098-97xx detector base.

These remote indicators are not suitable for connection to any other MAPNET II or IDNet module.

They are used where the fire detector is installed in an inaccessible location, and indication of alarm must be provided in an easily accessible area. For example, where the detectors are in roof spaces or cupboards, under the floor, or in hotel rooms, and indication is required in the room or corridor.



FEATURES

- Slimline design
- Easy to install
- Low current consumption
- Compatible with detectors fitted to a 4098-97xx detector base.

PRODUCT RANGE

Parts	Description
2098-1110	Fire Alarm in Roof Space
2098-1111	Fire Alarm in Concealed Space
2098-1112	Fire Alarm in Cupboard
2098-1113	Fire Alarm in Room
2098-1114	Fire Alarm in Return Air
2098-1115	Fire Alarm in Duct
2098-1116	Blank

COMPLIANCE

The 2098-1xxx range of Remote Indicators have been fully tested and approved by relevant authorities.

SPECIFICATION

Operating Voltage: 1.8V DC Typical
 (from 4098-97xx Base)

Alarm Current (Min): 1.6mA

Alarm Current (Max): 25mA at 45° C,
 15mA at 75° C

Luminous Intensity: as per AS2362.25-2004

Relative Humidity: 95% (n/cond.) max.

Ambient Temperature: -5° C to +75° C